



Inspection and Testing of Fire Alarm Systems Certification

Level I Content Outline

The candidate for NICET certification at Level I in Inspection and Testing of Fire Alarm Systems should have the knowledge and experience to:

Perform periodic inspections and tests of basic* fire alarm systems and prepare related records and reports.

**Basic fire alarm systems do NOT include the following: suppression interfaces, networked control units, smoke control interface, aspirating systems, multi-zone voice evacuation systems, high-rise applications, and job planning; but MAY include elements such as door releases, elevator recall, local duct detectors, local air handler shutdown, single-zone voice evacuation, etc.*

1.1 Plan and Coordinate Work

(Questions related to these tasks make up 24-34% of the exam.)

- 1.1.1 Determine the number, type, and location of devices to be inspected and/or tested.
- 1.1.2 Coordinate with the owner/building manager during inspection and testing.
- 1.1.3 Identify and apply the appropriate inspection and testing requirements for the job.
- 1.1.4 Issue notifications of testing as needed.
- 1.1.5 Identify impairments and issue appropriate notifications.
- 1.1.6 Restore the system.
- 1.1.7 File documentation and reports.

1.2 Inspect Equipment

(Questions related to these tasks make up 24-34% of the exam.)

- 1.2.1 Inspect system control units.
- 1.2.2 Inspect system power supplies, wiring, and connections.
- 1.2.3 Inspect initiating devices.
- 1.2.4 Inspect notification appliances.
- 1.2.5 Inspect equipment for off-premises signaling.
- 1.2.6 Inspect signal wiring and connections.

1.3 Test Functionality

(Questions related to these tasks make up 34-44% of the exam.)

- 1.3.1 Test functionality of system control units.
- 1.3.2 Test functionality of power supplies.
- 1.3.3 Test functionality of initiating devices and circuits.
- 1.3.4 Test functionality of notification appliances and circuits.
- 1.3.5 Test functionality of equipment and circuits for off-premises signaling.
- 1.3.6 Test functionality of basic interfaces.
- 1.3.7 Manually measure sensitivity of detectors (without accessing site-specific programming).

1.4 Maintain Devices

(Questions related to these tasks make up 5-13% of the exam.)

- 1.4.1 Replace batteries as needed.
- 1.4.2 Replace devices as needed.
- 1.4.3 Clean devices as needed.

Approved January 7, 2015